

# PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 72

Date 27/02/2026

It is certified that an inspection team headed by- **Nilesh chhatrapale Chemist** Public Heath Engineering Department Betul ( M.P. ) (Name of officers with designation) from Public Heath Engineering Department Betul ( M.P. ) inspected the Dreamz Play (Public) C.B.S.E. School Multai Distt -Betul (M.P.) ON 27/02/2026 And on the basis of Water Test Report ( Attached ) Bearing no. 72 Dated 27/02/2026 and URL No-TC17152600000049F of Water Testing Laboratory Betul (PHED LAB) certified that the Dreamz Play (Public) C.B.S.E.School Multai, Distt- Betul (M.P.) has Safe Drinking Water facilities for the students and members of staff of the institution, school is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/state/U .T. Govt.

This certificate is valid till - 06 Month,s



Signature with Seal. **Chemist**  
**Public Health Engineering Deptt.**  
**Betul (M.P.)**  
Name: Nilesh chhatrapale  
Designation: Chemist  
Public Heath Engineering Betul

To,  
**Dreamz Play (Public)C.B.S.E.School Multai,**  
**Distt- Betul (M.P.)**  
(Name and address of the institution)



Signature  
**Principal**  
Dreamz Play (Public)  
School Multai 1030887

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

**DISTRICT WATER TESTING LABORATORY**  
Public Health Engineering Department .P.H.E.D. Betul  
Near Satpuda club, Sadar, Betul (M.P.) 460001



**Test Report**

TC-17158

Location of performance Testing :- Laboratory		Not sampled by Lab	
Nature of sample:- Drinking Water		Unique Identification No.	DWTLBET
To DREAMZ PLAY (PUBLIC) C.B.S.E. SCHOOL MULTAI Amravati Road Multai Dist. Betul (M.P.)	Sender letter no.	302	Sender's letter Date
	Date of receiving sample	25/2/2026	Collection date of Sample
	LAB Ref. No	53	LAB Ref. Date
	Date of analysis started	25/2/2026	Date of analysis
	Quantity Of Sample	1 LTR	URL No. TC171526000000049F
	Type of Sample	R.O. Water	Environmental Condition - 23°C ± 5°C
	Discipline	Chemical	Group - Water

**Sample details**

No.	Particulars of Samples
1	R.O. Water Sample - Multai
2	

**RESULTS**

No.	Characteristics	Unit	Test methods	BIS-10500:2012 Reaffirmed in .2023		Results	
				Desirable Limit	permissible Limit	1	2
1	2	3	4	5	6	7	8
1	Taste	-	IS:3025 ( part 7 ) : 2017	Aggregable	Aggregable	Agg	-
2	Colour in	CU	IS:3025 (part 4)visual comparison	5	15	7	-
3	Odour	-	IS:3025 (part 5) : 2018	Aggregable	Aggregable	Agg	-
4	Chloride as CL	mg/l	IS:3025 (part 32) : 1988	250	1000	44	-
5	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS:3025 (part 23) : 2023	200	600	195	-
6	Calcium as Ca <sup>++</sup>	mg/l	IS:3025 (part 40):2024	75	200	34.4	-
7	Magnesium as Mg <sup>++</sup>	mg/l	IS:3025 (part 46):2023	30	100	7.79	-
8	Total Hardness as CaCO <sub>3</sub>	mg/l	IS:3025 (part 21) : 2023	200	600	118	-
9	pH	pH scale	IS:3025 (part 11)	6.5 to 8.5	6.5 to 8.5	7.12	-
10	Fluoride as F	mg/l	IS:3025 (part 60/sec 1) : 2023	1.0	1.5	0.49	-
11	Sulphate as SO <sub>4</sub>	mg/l	IS:3025 (part 24/sec 1) :2022	200	400	23.6	-
12	Turbidity	NTU	IS:3025 (part 10) : 2023	1.0	5.0	1.8	-
13	Conductivity at 25°C	micromhos/cm	IS:3025 (part 14)	-	-	410	-
14	TDS	mg/l	IS:3025 (part 16) : 2023	500	2000	246	-
15	R.Chlorine	mg/l	IS:3025 (part26) : 2021	0.01	0.2	0.01	-

**Disclaimer**

- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under " acceptable " render the water not suitable , but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternate source" in column 6, above with the sources will have to be rejected.
- The results refer only to tested sample and parameters tested.
- Samples will be stored for a period of 15 days from the date of issue of report.
- This lab dose not hold any responsibility for variation in results for samples kept on hold for want of clarification.

End of the test report



Reviewed by

Mrs. Anvita Singh

Technical In-charge

Issue No. 72 DWTL/PHED/BET/ Issue Date - 27/02/2026

Authorized Signatory  
Mr. Nilesch Chhatrapale  
Quality Manager

*(Signature)*  
Principal  
Dreamz Play (Public)  
School Multai 103088

**DISTRICT WATER TESTING LABORATORY**  
Public Health Engineering Department.P.H.E.D.  
Near Satpuda club, Sadar ,Betul (M.P.)460001

**Test Report**

Nature of sample- Drinking Water Sample/Others		Not sampled by Lab	Unique Identification No.	DWTLBET
TO, DREAMZ PLAY (PUBLIC) C.B.S.E SCHOOL MULTAI Amravati Road Multai Dist.Betul(M.P.)	Sander Letter No-	302	Sander Letter Date-	25/2/2026
	LAB Ref. No	53	LAB Ref. Date	25/2/2026
	Date of analysis started	25/2/2026	Date of analysis Completed	26/2/2026
	Discipline	Bacteriological	Group	Water
	Type of Sample	R.O. Water	Environmental Condition - 23°C ± 5°C	
	Quantity Of Sample	200 ml		

**Sample details**

NO.	Particulars of Samples
1	R.O. Water Sample - Multai
2	-

**RESULTS**

**PARAMETERS PROPOSED FOR SCOPE**

No.	Characteristics	Unit	Test methods	BIS-10500:2012 Reaffirmed in 2023		Results	
				Acceptable Limit	Permissible Limit	1	2
1	2	3	4	5	6		
2	Iron as Fe	mg/l	BIS:3025 part 53	1.0	1.0	0.1	-
3	Nitrate as NO3	mg/l	BIS:3025 part 34	45	45	10.3	-
4	Faecal Coliform (TTC)	per 100 ml	-	NIL		nil	-
5	Total Coliform	per 100 ml	-	NIL for treated water and water in		nil	-

**Disclaimer**

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under " acceptable " render the water not suitable , but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternate source" in column 6, above with the sources will have to be rejected.
3. The results refer only to tested sample and parameters tested.
4. This lab dose not hold any responsibility for variation in results for samples kept on hold for want of clarification.

End of the test report

Report reviewed by

*Darshini*  
Principal  
Dreamz Play (Public)  
School Multai 1030884

*A. S.*  
Chemist  
District Water Testing Lab  
P.H.E.D. Betul(M.P.)